

Design and Analysis of charge-reduced Refrigerant Cycles using R290

Dr.-Ing. Lena Schnabel^{1,*}, M.Sc. Timo Methler¹, Dr. Abdelrahman H. Hassan^{2,3}, Dipl.-Ing. Clemens Dankwerth¹, Prof. Dr. José María González Maciá²

Abstract Text

R290 is one of the most promising refrigerants for heat pumps and cooling processes working in a temperature range of -15-70 °C. The nearly neglectable global warming potential and attractive thermodynamic properties allow the design of climate-friendly and efficient refrigeration systems and heat pumps. However, R290 is flammable, and the use of charge reduced components and designs should be the first central step to reduce safety risks.

Whereas the prediction of heat capacity, temperatures and pressure drops are sufficiently precise the prediction of refrigerant charge is not very accurate when using computer-aided design tools. The article presents a method to enhance accuracy for refrigerant cycles with less than 500 g of R290.

Keywords: charge reduction, heat pumps, refrigerant cycle, propane, R290

Author affiliations

¹Fraunhofer Institute for Solar Energy Systems ISE, department of heating and cooling technologies, Heidenhofstr. 2, 79110 Freiburg, Germany.

²Instituto Universitario de Investigación en Ingeniería Energética, Universitat Politècnica de València, 46022, Valencia, Spain.

³Mechanical Power Engineering Department, Faculty of Engineering, Zagazig University, 44519, Zagazig, Egypt.

Email corresponding author: lena.schnabel@ise.fraunhofer.de

1 Introduction

The analysis of the European market for brine-to-water heat pumps for domestic heating, most of the systems work in a range of 6-16 kW and use refrigerant charges between 500 – 1000 g. To compare the different systems, the capacity specific charge was calculated and plotted for the heating capacities at the standard design point B0/W35 (see Figure 1). B0 stands for the source or brine temperature of 0°C and W35 means the heating water temperature of 35 °C.




Figure 1. Heating capacity specific refrigerant charge of market available brine-to-water heat pumps (dots) and target range (red) for a domestic heat pump system using 150 g of R290.

The total refrigerant charge of the systems in Figure 1 is indicated by iso-charge lines of 600, 500 and 150 g. The lowest iso-charge line of 150 g represents the safety limit of the DIN EN 378 defining those systems using max. 150 g of flammable refrigerant charge do not have to implement additional safety measures [1]. Combining this limit of 150 g for indoor installations with a typical heating demand of 5 - 10 kW for a single-family house or apartment results into the red marked area in figure 1 with a specific charge of 15 – 30 g/kW heating capacity.

The development of a charge reduced heat pump module, using max. 150 g of R290 and providing a heating capacity in the range of 5-10 kW with reasonable efficiencies is addressed with the project LC150, funded by the German Federal Ministry of Economic Affairs and Climate Action (BMWK) under the grant agreement number FKZ 03EN4001A and a consortium of 9 European manufacturers. The project aims to identify 2-3 attractive heat pump module designs and design knowledge on charge reduced refrigerant cycles. The first will support the manufacturer in offering faster indoor systems with R290. The second more generic aim creates design knowledge which will be helpful also for reducing charge and therefore enhancing safety of systems with larger capacities.

Charge reduced refrigerant cycles and heat pumps are under research for several years [2-13]. From this literature the most relevant aspects for charge reduction were identified and continued with an extensive experimental and simulation-based screening of components and cycles to improve design rules and accuracy in prediction. The main aspects considered here include, for example, reducing the amount of oil in the compressor, selecting plate heat exchangers with few plates, equal volume flow and inlet vapor quality distribution and small volume on the refrigerant side.

The presented work is still in progress. Due to this the contribution describes the methodology of the cross evaluation of refrigerant cycles, the simulation concept and first results of improved computer-aided system design.

2 Methodology

The design of refrigerant cycles is typically done by design tools using experimentally evaluated single components data. Since single component measurements are time consuming and that they do not cover the question of refrigerant charge of the cycle in total, the concept of cross-evaluation was developed. This means to experimentally evaluate one component in different cycle configurations: for example, the same evaporator in combination with different compressor types. The results give feedback on the specific cycle characteristics like efficiency, refrigerant charge and heating capacity. Analyzing the characteristics of different cycles with one identical component allows to identify the efficiency and refrigerant charge sensitive components and creates a database for the validation of the simulation tool. Wherever needed additional single component measurements were done to consolidate this concept.




Figure 2. Cross-evaluation method of the LC150 project.

Figure 2 illustrates the different parts of the cross-evaluation method. The first step is the cycle design. Different components are combined to cover a range of market available heat exchanger and compressor designs, control, and cycle concepts. Components were designed for a 4 kW, 8 kW and 12 kW version of the cycle based on simulations, manufacturer design tools and own experiences.

The second step was the definition of the operational envelop of the tests. In order to be able to compare all components and prototypes equally, the point B0/W35 was chosen. B0/W35 is used as baseline and is evaluated for a variation of compressor speed and superheat. For a global comparison, the seasonal COP (SCOP) was selected as the primary evaluation criterium. Therefore, additional operation points, like EN14825, are measured.

Refrigerant charge has a significant role in the performance of a heat pump; therefore, all varied operation parameters were measured for a charge up to 300 g of R290. The measurements were started with the lowest possible charge for stable operation and charge was added successively, in 10 g increments, until the cycle reaches his upper pressure limit. During every charge increment, all points of operation are measured if possible. All varied parameters add up to 20 individual measurements per charge increment and can be found in Table 1. Considering the charge increments every refrigerant cycle is measured for about 300-400 operation points.

Table 1. Varied parameters for the cross-evaluation measurements.

Charge [g]	Superheat [K]	Source Temperature [°C]	Sink Temperature [°C]	Compressor speed [%]
0 - 300	5, 10, 15	-7/0/10	24/27/30/34/ 35/45/55/65	10/40/70/100

All measurements, evaluating calculations and refrigerant charging operations were done fully automated, to increase reliability as well as speed in the measurement process. More details on the experimental set-up are described in [14].

The completion of the cross-evaluation method is given by the co-simulation of the experimentally evaluated refrigerant cycles and operational points. As simulation tool the software IMST-ART[®] is used. IMST-ART[®] [15] is a simulation tool based on physical models developed by the I.U.I. de Ingeniería Energetica at Universitat Politècnica de Valencia. It can be used to calculate the performance and the refrigerant charge of the vapor compression cycles.

Deviations between simulations and experimental results are discussed and analyzed more deeply. So far, additional single component measurements, calculation of thermal losses, thermographic pictures of the heat exchanger surfaces and geometrical evaluation of the internal volumes of the components were individually discussed, compared, or evaluated to get a more precise matching.

3 Application of the method

As mentioned above, several different heat exchangers, compressors and connecting tube designs were chosen to cover three different heating capacities and to represent different design concepts. All components were discussed with their manufacturers with specific areas of attention in mind, which were determined by previous measurements [16], literature studies and expert interviews. Table 2 shows the recent status of designed and evaluated refrigerant circuits with the combination of components. Within the table and the rest of the document “RC” stands for refrigerant circuit, the “8” stands for targeted 8 kW heating capacity.

Table 2. Characteristics of the different refrigerant circuits and their components. The highlighted circuit RC-8-09 is the reference circuit for the simulation and method evaluation within this article.

Versions ID	Compressor	Condenser*	Evaporator
RC-8-01	scroll high oil amount	long 20 plates 10:6.2 asymmetric*	long 36 plates symmetric
RC-8-02	rotary medium oil amount	long 20 plates 10:6.2 asymmetric*	long 46 plates 10:5 asymmetric*
RC-8-06	scroll high oil amount	medium length 40 plates 10:8.8 asymmetric*	long 36 plates symmetric
RC-8-08	rotary medium oil amount	special build not in general metrics	special build not in general metrics
RC-8-09	rotary medium oil amount	long 20 plates 10:6.2 asymmetric*	long 46 plates 10:5 asymmetric*
RC-8-10	scroll high oil amount	medium length 38 plates symmetric	long 36 plates symmetric
RC-8-16	rotary medium oil amount	medium length 18 plates symmetric	short 20 plates symmetric
RC-8-17	scroll high oil amount	medium length 38 plates symmetric	short 40 plates symmetric
RC-8-18	rotary medium oil amount	medium length 40 plates 10:8.8 asymmetric*	long 46 plates 10:5 asymmetric*
RC-8-21	horizontal scroll low oil amount	long 20 plates 10:6.2 asymmetric*	long 36 plates symmetric

RC-8-22	rotary medium oil amount	medium length 40 plates 10:8.8 asymmetric*	long 46 plates 10:5 asymmetric*
RC-8-26	scroll high oil amount	medium length 40 plates 10:8.8 asymmetric*	thermally very long 42 plates symmetric
* "10:x asymmetric" means the water side has a volume that is 10 divided by x larger than the refrigerant side.			

The highlighted refrigerant circuits RC-8-09 and RC-8-21 were chosen for a comparison in the result section. Refrigerant circuit RC-8-09 is used for detailed comparison between experimental data and simulation results.

The refrigerant circuit RC-8-09 is equipped with a hermetic twin rotary heat pump compressor. The compressor has a medium oil amount. The evaporator has 46 plates long and asymmetric heat exchanger.

On the other hand, the refrigerant circuit RC-8-21 is equipped with a very compact and semi hermetic automotive scroll compressor which allows very high compressor speeds and has a very low oil amount. The evaporator is a symmetric heat exchanger with a smaller number of plates than in refrigerant circuit RC-8-09. Both refrigerant circuits are using the same condenser.

From this position it can be expected that refrigerant circuit RC-8-21 requires less refrigerant charge due to the compressor and oil amount (RC-8-09 uses three to four times the oil amount of RC-8-21). Due to higher possible revolution of the compressor RC-8-21 it can be anticipated that this refrigerant circuit achieves a higher absolute heating capacity. Regarding the efficiency (COP) the prediction is not clear, because the evaporators are completely different and the overall efficiency highly depends on the performance of the evaporators. In RC-8-09 the evaporator has 46 plates and is asymmetric whereas in RC-8-21 the evaporator has less plates (36 plates) but is symmetric.

The following chapters describe the experimental and simulation-based analysis with their main parameters and steps. First, there is the experimental analysis giving results for the parameter variation as described in Table 1. Details of the experimental set-up and evaluated values are described in chapter 3.1. As evaluation criteria the COP and the heating capacity Q_{heat} of the different operation parameters are plotted as a function of the refrigerant charge C .

The comparison of experiment and simulation is done on that base using an additional step of plausibility check by first applying the simulation model to the single components. Details are described in chapter 3.2.

3.1 Experimental-based Analysis of the refrigerant cycle

Figure 3 shows the scheme of the experimental set-up. Brine at the evaporator (source) and water at the condenser (sink), are provided by conditioning modules. Those fluids are referred as secondary fluids. These modules have the following adjustable and controllable parameters: fluid temperature and mass flow. The conditioning module for the sink side is filled with water and the module on the source side with a mixture of ethylene/glycol and water with a freezing temperature of -20°C .

The sensors of the refrigerant cycle are installed anew when the cycle is changed to the next version.




Figure 3. Scheme of the experimental set-up for the analysis of the refrigerant cycles; with 8 temperature sensors (TRI), 2 differential pressure sensors (PDRI), 2 absolute pressure sensors (PRI), 2 pressure switches (PZH) and an electrical performance measuring device (E/I/J-RI).

Sensors and sensor positions are necessary to control the cycle and to calculate the relevant performance values. Table 3 shows the relevant values and their sensor position.

Table 3. Relevant measured and calculated performance values.

Value	Unit	Sensor number	Equation
evaporation temperature T_{ev}	[°C]	P100	$T_{ev} = T_{sat,R290}(P100)$
evaporator inlet temperature $T_{ev,in}$	[°C]	T107	-
evaporator outlet temperature $T_{ev,out}$	[°C]	T100	-
condensation temperature T_{cond}	[°C]	P104	$T_{cond} = T_{sat,R290}(P104)$
condenser inlet temperature $T_{cond,in}$	[°C]	T104	-
condenser outlet temperature $T_{cond,out}$	[°C]	T106	-
evaporator refrigerant pressure drop $dp_{ev,ref}$	[kPa]	dP108	-
condenser refrigerant pressure drop $dp_{cond,ref}$	[kPa]	dP105	-
superheat SH	[K]		$T_{ev,in} - T_{ev}$
power consumption compressor $P_{comp,tot}$	[kW]	P_{el}	

Heating capacity Q_{heat}	[kW]	Q_{heat}	$\dot{m}_{cond,water} * (T201 - T200) * c_{p,water}$
Cooling capacity Q_{cool}	[kW]	Q_{cool}	$\dot{m}_{ev,brine} * (T205 - T203) * c_{p,brine}$

For evaluation all relevant values were measured or calculated. The electrical power consumed by the driver and compressor $P_{comp,tot}$ was measured between the driver and the power grid. Therefore, all frequency converter losses are included.

The cooling and heating capacities on the source and sink side (secondary sides) were calculated by the measurement of the mass flow employing a coriolis sensor, combined with in- and outlet temperature measurement, using submerged PT100 sensors.

Estimating the power necessary for external pumps on the secondary side, differential pressures across the heat exchangers on the secondary side were monitored by differential pressure sensors. Controllers were used to control the inlet temperature by adjusting cooling rate employing the building wide cooling network. The temperature difference between in- and outlet of the two plate heat exchangers on the secondary sides, were controlled by adjusting the mass flows of secondary fluids. A temperature difference of 3 K was set on the source side and a temperature difference of 5 K was set on the sink side within the secondary fluids to better emulate the EN14825 standard measurements. The suction-side superheat of the refrigerant circuit was controlled with common PID controller employing an electronic expansion valve.

All measurements relied on adjusting the charge employed to the refrigerant circuits. For this purpose, a special charging station was developed and constructed, with the specific task in mind to ensure accuracy, reliability, automated charging, and safe discharging of up to three refrigerant circuits in parallel. The principle is described more detailed in [14]. The accuracy of the charging process is about +/- ("charging mass" * 20 % + 3 g) with knowledge of the charged amount +/- 0.3 g

The experimental data are processed by an automated calculation and visualization and of the relevant process parameters. As a summary for each refrigerant cycle measurement the COP and heating capacity as a function of refrigerant charge is plotted. For the comparison of different operation points a performance map showing the efficiency and the regions of critical charge was developed.

For the comparison between simulation and experiment six values were chosen: the COP, the heating capacity Q_{heat} , the evaporation temperature T_{ev} , the condensation temperature T_{cond} , the electric power consumption of the compressor $P_{comp,tot}$ and the refrigerant charge C .

3.2 Database of simulation components

3.2.1 Heat exchangers

The methodology used to model and validate the heat exchangers starts with the available datasheet and technical drawings provided by each manufacturer.

Table 4. Correlations used to calculate the heat transfer coefficients (HTC) and the frictional pressure drop coefficient (FC) inside the BPHXs (brazed plate heat exchangers).

Component		Condenser	Evaporator
Refrigerant-side (single-phase) and secondary fluid side	HTC	Dittus et al. [18]	
	FC	IMST-ART® [19]	
Refrigerant-side (two-phase)	HTC	Shah [20]	Chen [21]
	FC	Friedel [22]	

From this data, the main specifications are extracted or assumed and then provided as inputs to an Engineering Equation Solver [17] (EES) code. This code uses the plate thickness as the iterative variable to obtain the proper refrigerant-side hold-up volume indicated by the manufacturer. The third step is to model the brazed plate heat exchanger (BPHX) using the “Stand-alone Analysis” feature of IMST-ART[®], where the inputs to the model are the outputs from the EES code. The main correlations used for evaluation are the heat transfer coefficient (HTC), and frictional pressure drop coefficient (FC) inside the heat exchangers for single- and two-phase flows. They are summarized in Table 4.

Finally, the results from IMST-ART[®] are validated with the manufacturer's design point values. The main comparison variables, in the case of heat exchangers, are the condensation/evaporation temperature (T_{cond}/T_{ev}), heating/cooling capacity (Q_{heat}/Q_{cool}) and refrigerant-side pressure drop ($dp_{ev,ref}$).

IMST-ART[®] successfully estimates the catalog data for condensers and evaporators of the database. The estimated T_{ev} and T_{cond} values are within ± 1 K error bands, while the heating/cooling capacity (Q_{heat}/Q_{cool}) and $dp_{ev,ref}$ values are within $\pm 10\%$ error bands. These deviations are acceptable for modeling heat exchangers.

3.2.2 Compressors

The manufacturers characterize the compressors using AHRI correlations with ten coefficients with a fixed compressor speed, subcooling SC and superheat SH values [23]. These correlations are used to calculate the mass flow rate \dot{m}_{ref} , electrical power consumption $P_{comp,tot}$, and cooling/heating capacity as a function of evaporation and condensation temperatures. However, in order to accurately estimate the compressor performance under different speeds and evaporating and condensing temperatures, it is better to convert these correlations to performance tables where IMST-ART[®] can interpolate to find the required cooling capacity and electrical power consumption of the compressor ($P_{comp,tot}$). Then based on this data, it will be easy to calculate the main parameters of the compressors: volumetric efficiency (η_v), compressor efficiency (η_{comp}), and isentropic efficiency (η_{is}), as indicated by Eq. 1, Eq. 2, and Eq. 3, respectively.

$$\eta_v = \frac{\text{actual volume flow}}{\text{theoretical swept volume} \times \text{compression speed}} = \frac{v_{suc} \cdot \dot{m}_{ref}}{V_{swept} \cdot n_{comp}} \quad \text{Eq. 1}$$

$$\eta_{comp} = \frac{\text{isentropic work required for compression}}{\text{total electrical power consumption}} = \frac{\dot{m}_{ref}(h_{dis,is} - h_{suc})}{P_{el}} \quad \text{Eq. 2}$$

$$\eta_{is} = \frac{\eta_{comp}}{1 - \Phi_{loss}} \quad \text{Eq. 3}$$

\dot{m}_{ref} is the mass flow of the refrigerant [kg/s] calculated based on the cooling capacity. Φ_{loss} is the heat losses percentage from the electrical power consumed by the compressor [%]. This is an important factor that affects the discharge temperature and isentropic efficiency. This factor is difficult to estimate, and it should be updated based on the actual experimental results.

To convert the AHRI correlations to performance table, the visual basic for application (VBA) in Excel combined with the CoolProp [24] add-in were used. The IMST-ART's feature “Stand-alone Analysis” is used to model the compressors as well as the heat exchangers.

The main comparison variables, in the case of compressors are the mass flow rate \dot{m}_{ref} and electrical power $P_{comp,tot}$. All parameters are within a deviation of $\pm 3\%$, compared to the view specific points indicated in provided datasheets. One of the main sources of these deviations is the linear interpolation in the catalog correlations and IMST-ART[®] performance tables.

3.3 Simulation-based analysis of the refrigerant cycle

Using the available database of models using the above method, all circuits measured in the laboratory can be created dynamically as independent and automated simulation. This includes the prepared models as well as, the piping dimensions (e.g., material, length, diameter) and a basic representation of the insulations. To complete the comparison to the measurements, the measurements matrix must be mirrored in the parametric study of the simulation.

Based on the baseline configuration of B0/W35/SH10/F40%, every parameter (i.e., source inlet temperatures, sink outlet temperatures, super heat, compressor frequency) was iterated with fixing of all other parameters (e.g., compressor frequency was iterated from 10%, 40%, 70%, 100% while fixing the other parameters to the baseline configuration B0/W35/SH10). Based on the measurement matrix (see Table 1), superheat has 3 iterations (5, 10, 15 K), as well as source temperature (-7, 0, 10 °C), while the sink temperature has 8 iterations; the first 4 sink temperatures were for the low, moderate, medium, and high temperature applications (35, 45, 55, 65°C), besides, the last 4 iterations were parts loads based on DIN14825 (34, 30, 27, 24 °C). All parameters' iterations resulted in 21 cases while fixing the charge. On the other hand, refrigerant charge was iterated between 10 to 250 g propane with an increment of 5 g, resulting in a total of 1,050 simulations for all component combinations.

All simulations are built, started and results collected using a python interface/script and compared against the measurement data. The automation of this process, which is still under development, will give an extensive picture of prediction reliability and needs for improvement. With this the comparisons will be basis for future adaptations to the IMST-ART[®] simulation environment. In preparation for the evolution of the simulation environment, areas of attention have been identified based on pre-measurements and first manual simulations.

4 Results and Discussion

The following results (Figure 4 and Figure 5) show the variation of heating capacity Q_{heat} and COP for the operation point B0/W35 with a superheat of 10 K and 40 % of compressor speed as a function of refrigerant charge for the refrigerant circuits RC-8-09 and RC-08-21.

Both investigations are starting with a very low amount of refrigerant charge (90 g and 100 g). In this case the refrigerant circuit is charged with insufficient refrigerant. The refrigerant is not fully condensed in the condenser and is not fully liquid in front of the expansion device. The expansion device opens up to 100 % to ensure 10 K super heat but does not succeed. The super heat is higher than 10 K. Due to this fact both, heating capacity and COP are rising with increasing charge until the refrigerant is completely liquid in front of the expansion device. The trend of the graphs are reaching a plateau. The first point of charge reaching this plateau is identified as "minimum efficient charge" and indicate the value which is needed to run the process with stable conditions at minimum charge and with maximum efficiency (red circle). The blue column marks the region of 150 g refrigerant charge. For the RC-8-09 the minimum efficient charge is about 170g of R290, for the RC-08-21 this value is with 120 g smaller. Precisely addressing the limit of 150 g (blue column) the cycle RC-08-21 meets this requirement. The COP in figure 5 drops down after passing the plateau with increasing amount of refrigerant charge in the system. In this case the system is overcharged. There is no liquid receiver in the system and thus additional refrigerant charge is hold up in the liquid line and afterwards in the condenser. Because of extra refrigerant in the condenser the heat transfer area in the condenser itself is smaller. The smaller the heat transfer area is, the higher needs to

be the temperature difference between refrigerant and sink fluid (water). The higher the condensing temperature the higher absolute pressure (high pressure side) and therefore the pressure difference is higher. This results in higher power consumption of the compressor which leads to smaller COPs.

Additionally, RC-08-21 realizes higher heating capacities Q_{heat} . The reason for that can be found in the combination of components (see table 2). The condenser of both cycles is identical, but the compressor of RC-8-09 is a rotary compressor with a medium oil amount whereas for RC-8-21 a horizontal scroll with a low oil amount was used. The used evaporator was similar in length, but for RC-8-09 an asymmetric design with 46 plates was applied whereas RC-8-21 used an evaporator with a symmetric design and 36 plates.




Figure 4. Experimentally evaluated heating capacity Q_{heat} for RC-8-09 and RC-8-21 at B0/W35, superheat of 10 K, compressor speed of 40 % as a function of refrigerant charge.

The changes illustrate the relevant aspects for charge reduction, the amount of oil and the total volume of the compressor and the design and operation of the heat exchangers. Asymmetric designs are promising with respect to charge reduction, in the case of RC-8-09 the asymmetric design combined with a high number of plates led to maldistribution of the refrigerant mass flow and inlet vapor quality in the evaporator. This results into a higher need of refrigerant in this component and is contrary to the design intention.




Figure 5. Experimentally evaluated COP for RC-8-09 and RC-8-21 at B0/W35, superheat of 10 K, compressor speed of 40 % as a function of refrigerant charge.

Figure 5 illustrates the efficiency of the two different refrigerant cycles. For the RC-8-21 a maximum COP of 4,5 is reached at 120 g of refrigerant charge. Enhancing the charge up to 160 g is not affecting the COP, with higher charges the COP decreases due to increasing inefficiencies in component operation. The behavior of the RC-8-21 is similar but shifted to higher refrigerant charges.

In order to compare the results of simulation and experiment six characteristic values were defined in chapter 3.1.: the COP, the heating capacity Q_{heat} , the evaporation temperature T_{ev} , the condensation temperature T_{cond} , the electric power consumption of the compressor $P_{comp,tot}$ and the refrigerant charge C .

Figure 6 shows the deviation between simulation and experiment in percent for four different compressor speeds. 30 rps (rounds per second = Hz) corresponds to the mentioned 10 % of max. compressor speed, 60 rps \approx 40 %, 90 rps \approx 70 % and 120 rps \approx 100 %. The values are compared with the assumption that the minimum efficient charge value should show the same behavior. This point is marked in Figure 4 and Figure 5 by a red circle. The minimum possible compressor speed is referred to 0 % (in this case 20 rps for this specific compressor). The maximum possible compressors speed is referred to 100 % (in this case 120 rps for this specific compressor). Between the min and max limit, the compressor speed is behaving linear. The min and max limit can be different for other compressor models. Thus, with a compressor speed of 60 % two different compressor do not have to have the same compressor speed in rps necessarily.

The results shown in Figure 6 give a very good agreement of lower than 10 % deviation between experiment and simulation for the COP and the heating capacity Q_{heat} , lower than 1,5 K deviation for the evaporation temperature T_{ev} and the condensation temperature T_{cond} and lower than 4 % deviation for the electric power consumption of the compressor $P_{comp,tot}$. As already mentioned before the estimation

of refrigerant charge is strongly underestimated by the simulation, the total values are in a range of 45 - 80 g.

A deeper analysis was and is done to understand this deviation and to integrate this sufficiently in the simulation software. The main areas of attention and their predicted impact is as followed:

- the volume of the heat exchanger ports is typically not considered, the predicted impact is a less steep performance increase in the “undercharge” region as well as a general increase in predicted necessary charge.
- A part of the refrigerant is absorbed in the oil; oil adsorption models are needed to describe this effect globally, but additionally there is just little known about the direct impact on performance since this impact is included in the compressor performance provided by the manufacturer. Oil absorption increases significantly the needed refrigerant charge.
- Oil sump location, the oil sump can be located on the discharge side of a compressor, or the suction side of a compressor. This results into strongly deviating pressures and temperature (12 bar versus 3 bar/ 70 °C versus 5 °C) which will impact the predicted amount of charge needed.




Figure 6. Deviation (blue dots) between simulation and experiment for the COP, the heating capacity Q_{heat} , the evaporation temperature T_{ev} , the condensation temperature T_{cond} , the electric power consumption of the compressor $P_{comp,tot}$ and the refrigerant charge C . Evaluated for the RC-8-09 at B0/W35, superheat of 10 K at the minimum efficient charge for varying compressor speed F from 30 rps to 120 rps.

5 Summary and Conclusions

With this work an evaluation method using an extensive experimental and simulation-based evaluation of refrigerant circuits to generate more reliable design knowledge for low refrigerant charge application was introduced.

The results show a very good agreement between the experimental and simulation-based data for the reference refrigerant cycle RC-8-09 for the thermophysical performance values, the deviation is in the order of the uncertainty of the experiments.

The simulation strongly underestimated the amount of refrigerant needed in the experiments. This was already assumed in the beginning of the project and led to several more detailed analyses, which allowed to identify the decisive parameters as geometrical uncertainties of the heat exchangers and the absorption of refrigerant in the oil of the compressor.

The work on comparing experimental and simulation-based results will be continued within the next months and the extensive database will be used to improve the precision of refrigerant charge estimation

for low-charge refrigerant cycles, but also to generate more component-based knowledge to identify design rules taking the whole operational envelop of a refrigeration circuit into account.

Acknowledgment

The work presented in this paper received funding from the German Federal Ministry of Economic Affairs and Climate Action (BMWK) under the grant agreement numbers FKZ 03EN4001A (LC150).

The cooperation between Fraunhofer ISE and UPV and the ideas for this work were inspired, supported and supervised by Prof. José Miguel Corberán Salvador. He served as Professor in the Department of Applied Thermodynamics and Director of the Institute for Energy Engineering at the Polytechnic University of Valencia (UPV), Spain and died on July 7, 2022 at the age of 65. We will continue the work with his attitude towards professionalism in refrigeration, cooperation and humanity.

Picture and short CV



Dr.-Ing. Lena Schnabel leads the Department “Heating and Cooling Technologies” at Fraunhofer ISE. She obtained her PhD from the Technical University in Berlin in 2009. Her research activities focus on heat and mass transfer in adsorption and vapor compression systems, refrigerant charge reduction, evaporation of water at low pressures and new heat exchanger designs.



MSc. Timo Methler is a researcher and project leader at Fraunhofer ISE. He obtained his MSc. in Karlsruhe, from the Karlsruhe Institute of Technology (KIT), in 2018. He mainly works in the experimental analysis of heat pumps, air conditioning components and systems, with special focus on R290 refrigerant reduction and is part of the core LC150 Team.



Dipl.-Ing. Clemens Dankwerth is a researcher, project leader and laboratory manager at Fraunhofer ISE and working since 2012 in the field of refrigeration and heat pumps. Recently he mainly works in the central project management of the project LC150 and several industry studies on heat pump designs with R290.



Abdelrahman H. Hassan is a postdoctoral fellow and adjunct professor at the Universitat Politècnica de València (UPV). He obtained a Ph.D. degree in industrial production and engineering, from the UPV, in 2016. He mainly works in numerical modeling of refrigeration and air conditioning components and systems. He has published more than 24 articles in various scientific journals and conferences in this field.



Prof. Dr. José María González Maciá is a Professor of the Department of Applied Thermodynamics at the Universitat Politècnica de València (UPV), leading the Division of Refrigeration and Heat Pumps.

Symbols used

c_p	[kJ kg ⁻¹ K ⁻¹]	specific heat capacity
C	[g]	charge/ mass of refrigerant
h	[kJ kg ⁻¹]	specific enthalpy
\dot{m}	[kg s ⁻¹]	mass flow
n	[s ⁻¹]	compressor speed
p	[kPa]	pressure
P	[kW]	electric power consumption
Q	[kW]	heating/ cooling capacity
T	[°C]	temperature
V	[m ³]	volume

Greek letters

Φ	[%]	Loss factor
η	[-]	efficiency

Sub- and Superscripts

brine	brine
cool	cooling
comp	compressor
cond	condensation/ condenser
dis	discharge (side of the compressor)
el	electric
ev	evaporation/ evaporator
Heat	heating
in	inlet
is	isentropic
loss	losses
out	outlet
ref	refrigerant
sat	saturation
suc	suction (side of the compressor)

swept	swept
tot	total
v	volumetric
water	water

Abbreviations

AHRI	Air-Conditioning, Heating, and Refrigeration Institute
B	brine
BPHX	Brazed Plate Heat Exchangers
COP	Coefficient of Performance
EES	Engineering Equation Solver
E/I/J-RI	Electrical Voltage, Current, Power, Recording, Indicating
FC	Frictional pressure drop Coefficient
HTC	Heat Transfer Coefficient
RC	Refrigerant Cycle
rps	rounds per second
PRI	Pressure, Recording, Indicating
PCRI	Pressure, Controlling, Recording, Indicating
PDRI	Pressure Difference, Recording, Indicating
PZH	Pressure, emergency value
SC	Subcooling
SCOP	Seasonal Coefficient of Performance
SH	Superheat
TRI	Temperature, Recording, Indicating
TCRI	Temperature, Controlling, Recording, Indicating
W	Water

References

- [1] European Committee for Standardization, **2016**. EN 378-1:2016 Refrigerating Systems and Heat Pumps - Safety and Environmental Requirements - Part 1: Basic Requirements, Definitions, Classification and Selection Criteria. European Committee for Standardization, n.d. EN 14511-3 Air conditioners, liquid chilling packages and heat pumps for space heating and cooling and process chillers, with electrically driven compressors - Part 3: Test methods [WWW Document]. URL https://www.techstreet.com/standards/din-en-14511-3?product_id=2076455 (accessed 9.21.21).
- [2] R. Ghouali, P. Byrne, F. Bazantay, Refrigerant charge optimisation for propane heat pump water heaters. *Int. Journal of Refrigeration* **2017**, *76*, 230–244.
- [3] P. S. Hrnjak, M. R. Hoehne, Charge minimization in systems and components using hydrocarbons as a refrigerant, ACRC Technical Report 224, **2004**, <https://hdl.handle.net/2142/12315>.
- [4] F. Poggi, H. Macchi-Tejeda, D. Leducq, A. Bontemps, Refrigerant charge in refrigerating systems and strategies of charge reduction. *Int. Journal of Refrigeration* **2008**, *31*, 353–370.

- [5] A. Cavallini, E. da Riva, D. del Col, Performance of a large capacity propane heat pump with low charge heat exchangers. *Int. Journal of Refrigeration* **2010**, *33*, 242–250.
- [6] D. Clodic, L. Palandre, Refrigerant capacity ratio as an indicator to evaluate advance technology for low charge refrigerant systems., in: Zero Leakage–Minimum Charge. IIF–IIR. Stockholm, Suede, **2002**.
- [7] P. Fernando, B. Palm, P. Lundqvist, E. Granryd, Propane heat pump with low refrigerant charge: Design and laboratory tests. *Int. Journal of Refrigeration* **2004**, *27*, 761–773.
- [8] B. Xu, Y. Wang, J. Chen, F. Li, D. Li, X. Pan, Investigation of domestic air conditioner with a novel low charge microchannel condenser suitable for hydrocarbon refrigerant. Measurement: *Journal of the International Measurement Confederation* **2016**, *90*, 338–348.
- [9] K. Andersson, E. Granryd, B. Palm, Water to water heat pump with minimum charge of propane. In: *13th IIR Gustav Lorentzen Conference on Natural Refrigerants: Natural Refrigerant Solutions for Warm Climate Countries, 18 June 2018 through 20 June 2018*. International Institute of Refrigeration, **2018**, 725-732.
- [10] B. Palm, P. Fernando, K. Andersson, P. Lundqvist, O. Samoteeva, **2005**, Designing a Heat Pump for Minimum Charge. *IEA HPC newsletter*, *232*, 17-1.
- [11] C. Dankwerth, T. Methler, T. Oltersdorf, P. Schossig, L. Schnabel, 2020, Experimental Evaluation of a charge reduced Heat Pump Module using 150g of Propane. In: *14th IIR Gustav Lorentzen Conference on Natural Refrigerants: Natural Refrigerant Solutions for Warm Climate Countries*. International Institute of Refrigeration, **2020**.
- [12] E. Navarro-Peris, L. Alvarez-Piñeiro, L. Schnabel, J. M. Corberán: Refrigerant maldistribution in brazed plate heat exchanger evaporators. Part B: Analysis of the influence of maldistribution on the evaporator performance. *Int. Journal of Refrigeration* **2021**, *131*, 312-321.
- [13] J. M. Corberán, I. O. Martínez, J. González. Charge optimisation study of a reversible water-to-water propane heat pump. *Int. Journal of Refrigeration* **2008**, *31*, 716-726.
- [14] T. Methler, C. Dankwerth, L. Joos, H. Fugmann, K. Morawietz, L. Schnabel. Experimental Analysis of Various Refrigerant Circuit Component Combinations for Low Charge Propane Heat Pumps. In: *15th IIR Gustav Lorentzen Conference on Natural Refrigerants: Natural Refrigerant Solutions for Warm Climate Countries, 13 June 2022 through 15 June 2022*. International Institute of Refrigeration, **2022**. DOI: 10.18462/iir.gl2022.171
- [15] J. M. Corberán, J. González-Maciá, IMST-ART, a computer code to assist the design of refrigeration and air conditioning equipment, IMST, Universitat Politècnica de València, Spain, **2009**.
- [16] C. Dankwerth, T. Methler, T. Oltersdorf, P. Schossig, L. Schnabel, Kältemittelreduktion in Propan-Wärmepumpen – aktuelle Arbeiten. Presentation at: *DKV Jahrestagung, 19.-20.11.2020, Ulm*. **2022**. DOI: 10.18462/iir.gl2022.171.
- [17] S. A. Klein, “Engineering Equation Solver (Version V10.451), F-Chart Software.” F-Chart Software, **2018**.
- [18] F. W. Dittus, L. M. K. Boelter, “Heat Transfer in Automobile Radiators of the Tubular Type,” *University of California Publications in Engineering* **1930**, *2*, 443–461.
- [19] IMST-ART, “Simulation Tool to Assist the Selection, Design and Optimization of Refrigeration Equipment and Components,” *Instituto Universitario de Investigación en Ingeniería Energética, Universitat Politècnica de València, Valencia*, **2010**. <http://www.imst-art.com/>
- [20] M. M. Shah, “A general correlation for heat transfer during film condensation inside pipes,” *Int. Journal of Heat and Mass Transfer* **1979**, *22*, 547–556.

-
- [21] J. C. Chen, "Correlation for Boiling Heat Transfer to Saturated Fluids in Convective Flow," *Industrial & Engineering Chemistry Process Design and Development* **1966**, 5, 322–329.
- [22] L. Friedel. "New friction pressure drop correlations for upward, horizontal, and downward two-phase pipe flow." *HTFS Symposium, Oxford*. **1979**.
- [23] STANDARD, A.H.R.I. Performance Rating Of Positive Displacement Refrigerant Compressors and Compressor Units. *AHRI Standard*, **2015**, 540. Jg.
- [24] I. H. Bell, J. Wronski, S. Quoilin, and V. Lemort, "Pure and pseudo-pure fluid thermophysical property evaluation and the open-source thermophysical property library coolprop", *Industrial and Engineering Chemistry Research* **2014**, 53, 2498–2508.

WILEY-VCH